


CEILING STRUCTURE -

-4" SQUARE JUNCTION BOX

1 DETAIL—CEILING MOUNTED SPEAKER E5.1 SCALE: 1/8" = 1"-0"



DUCT SMOKE DETECTOR (DSD) CIRCUIT RED (AHU-029-64 RM 136 MEZZAINE

o / o

2 DETAIL—LIGHTING FIXTURE MOUNTING E5.1 SCALE: 1/6" = 1'-0"

RM.136B

RM.136

BLK (/

RED (7

WHT RM.136A

FIRE ALARM CONNECTION DIAGRAM

SCALE: 3" = 1'-0"

RM.136B

12 GA. WIRE HANGERS AT TWO ENDS OF LIGHTING FIXTURE

SUSPENDED ACOUSTIC CEILING

ALL CIRCUITS TO
(E) FACT.
SEE DWG. 2.2
KEY NOTE

CEILING JOIST

2' x 4' FLUORESCENT LIGHTING FIXTURE, LAY-IN TYPE

AUDIO/VISUAL CIRCUIT

MANUAL PULL STATION CIRCUIT

F. CAPRISTO 5/14/99

A. HEVENER 5/14/99

J. KIM 5/14/99

4B64E082 E5.1

-(E) PULL STATION

CONFORMED 6/17/99

ı		1	AD	AH	JK	3/10/00	50% SUBMITTAL	BUILDING 64
	Daniel.	2	40	AH	JK	4/10/00	100% SUBMITTAL	
	Mann, Johnson, &	3	8	AH	JK	8/14/00	100% SUBMITTAL CONSTRUCTION DOCUMENTS	HIGH BAY RENOVATION
	Johnson, & Mendenhall							ELECTRICAL DETAILS
	Mendennan							ELECTRICAL DETAILS
	530 Bush Street, Suite 900							UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY LABORATORY
	Son Francisco, CA 94108-3623 (415) 986-1373							FACILITIES DEPARTMENT
	(,			CHECHED	400	ME	rouns	FACILITIES DEPARTMENT